



## Fire Prevention & Inspections Office

Black Mountain Fire Department

106 Montreat Road

Black Mountain, NC 28711

### Checklist for Reoccupying of Vacant Buildings

- 1-Install Fire Sprinkler System
- 2-Install Fire Alarm System
- 3-Provide two means of egress
- 4-Provide proper signage for the two means of egress
- 5-Install emergency lighting
- 6-Provide documentation of any and all hazardous materials to be stored or used on the premises
- 8-Provide evacuation plans
- 9-Install two fire extinguishers with a minimum 2A:10B: C rating

Completion of the checklist above does not alleviate the owner, tenant or any contractors from having to correct any and all Fire Code violations found during field inspections. If any questions arise please contact this office at 828.419.9333.